



TFT CERTIFICATION

DIAMOND MARK SCHEME

Test Certificate

Manufacturer/importer:	PT Kutai/Hanson Plywood Ltd
Product name/ref. (if applicable):	SP101 Plywood for flooring overlayment and other non-structural purposes
Scheme Member Licence Number:	DM P52005 (PT Kutai); DM P52003 (Hanson Plywood Ltd)
Relevant standard/specification:	'Model Specification for SP101 Plywood (Various Thicknesses)'; document ref. TFT/PLY/SP102/SPEC01 (Based on Contract Flooring Association (CFA) 'Guidance Note: Plywood for Overlaying Suspended Floors' Issue v1 July 2013)

During indicative batch testing, this product was found to comply with the appropriate standard/specification in respect of the following criteria:

- Deviation from nominal thickness: satisfactory as per CFA Guidance Note
- Density: satisfactory as per SP101 Model Specification (>300kg/m³)
- Layup faults - including core gaps, overlaps etc: satisfactory as per BS 1088-1:2003
- Face quality: satisfactory to Class I as per EN 635-2:1995
- Fibre adhesion in indicative glue bond testing: EN 314-2:1993 Class 3

Note: this product should satisfy the forthcoming Standard BS 8203:2017

Our reference:	TFT/50/16
Date of batch sample collection:	19 th October 2016
Testing completed and certificate updated/confirmed/re-issued:	20 th December 2016
Date of expiry of current Diamond Mark scheme membership certificate:	December 2017
Testing conducted by:	Simon Brock

Simon Brock TIMMM
Associate

The Diamond Mark is a recognised Quality Mark registered with the Intellectual Property Agency

TFT WOODEXPERTS LIMITED
(registered company no. 8080063)

Park House • Barker Business Park • Melmerby Green Road • Melmerby, nr Ripon • HG4 5NB • United Kingdom
www.technologyfortimber.co.uk • tel: +44 (0) 1765 60 10 10 • fax: +44 (0) 1765 60 80 81 • info@woodexperts.com